


TÜV NORD CERT GmbH
herewith declares that

Australian Premium Solar PTY LTD.
4/29 Bellrick street, Acacia Ridge
4110 Brisbane, QLD
Australia

is authorized to provide the product mentioned below with the mark as illustrated:



Description of product (details see Annex 2):

PV Modules with 6" Mono-crystalline Silicon Solar Cells

PV Modules with 5" Mono-crystalline Silicon Solar Cells

PV Modules with 6" Poly-crystalline Silicon Solar Cells

Tested according to: IEC 62716:2013
Registered No.: 44 780 16 406749 - 165
Manufacturer: see Annex 1
Test Report No.: 492010702.001
File No.: SHV04081/16-02

Valid until: 2021-09-13



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Essen, 2016-09-14

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: 44 780 16 406749 - 165

Seite / Page 1 von / of 1

Aktenzeichen: / File reference: SHV04081/16-02

2016-09-14

Manufacturer:

Manufacturer:

Australian Premium Solar (India) PVT. LTD.

Plot No.143, Road 4-A, GIDC, Kathwada, Ahmedabad 382430, Gujarat
India

Factory inspection report no.:

862010253.002

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.

A handwritten signature in blue ink, appearing to read "Rajesh K.", written in a cursive style.

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:

PV Modules with 6" Mono-crystalline Solar Cells:

72 cells: APSAM6-xxx/72 (xxx= 260-315W in increments of 5)

60 cells: APSAM6-xxx/60 (xxx= 215-265W in increments of 5)

54 cells: APSAM6-xxx/54 (xxx= 195-235W in increments of 5)

48 cells: APSAM6-xxx/48 (xxx= 175-210W in increments of 5)

36 cells: APSAM6-xxx/36 (xxx= 130-160W in increments of 5)

PV Modules with 5" Mono-crystalline Solar Cells:

96 cells: APSAM5-xxx/96 (xxx= 225-270W in increments of 5)

72 cells: APSAM5-xxx/72 (xxx= 165-205W in increments of 5)

36 cells: APSAM5-xxx/36 (xxx= 85-100W in increments of 5)

PV Modules with 6" Poly-crystalline Solar Cells:

72 cells: APSAP6-xxx/72 (xxx= 265-320W in increments of 5)

60 cells: APSAP6-xxx/60 (xxx= 220-265W in increments of 5)

54 cells: APSAP6-xxx/54 (xxx= 195-240W in increments of 5)

48 cells: APSAP6-xxx/48 (xxx= 175-215W in increments of 5)

36 cells: APSAP6-xxx/36 (xxx= 130-160W in increments of 5)

Maximum system voltage:

1000V

Fuse rating:

15A

Application class:

Class A

Electrical protection class:

Class II

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products